

PL-528

Liquid Static Pressure Sensor



Features:

- Suitable for water, steam (with PL-HS) or air
- Compact rugged construction
- Negligible temperature influence
- Supply short circuit & polarity reversal protected

Technical Overview

The PL-528 range of static pressure transmitters is suitable for use with liquids and non-aggressive gases compatible with the FPM (Viton seal).

The pressure transmitter is based on proven ceramic technology for exceptional performance speed and reliability.

Specification:

Output:	PL-528-x	4-20mA (2-wire loop powered)
	PL-528-x-V	0-10Vdc
Supply voltage:	4-20mA	7 to 33Vdc
	0-10Vdc	12 to 33Vdc or 24Vac \pm 15%
Load:	4-20mA	$\leq \frac{\text{Supply voltage} - 7V}{\text{Ohm}}$
	0-10Vdc	>10Kohm
Current consumption:	4-20mA	<23mA
	0-10vdc	<7mA
Electrical connections	DIN EN175301-803-A	
Accuracy @ 25°C, 45% RH 24Vdc supply:		
	Characteristic line	\pm 0.3 % fs
	Resolution	0.1% fs
	Thermal characteristic	\pm 0.2 % fs/10K max.
Response time	<2ms, 1ms typical	
Load cycle	<100Hz	
Overload/rupture:		
	0 to 4bar versions	3 x measuring range fs
	6 to 40 bar versions	2.5 x measuring range fs
Materials in contact with the medium	Stainless steel 1.4305/AISI 303 FPM (Viton) & Ceramic Al ₂ O ₃ (96%)	
Temperature:		
	Media	-15 to 125°C
	Ambient	-30 to 85°C
Dimensions	104 x 65mm	
Pressure connection	½" BSP male manometer combi	
Protection	IP65	
Conformity	EN 61326-2-3, CE Marked, EMC	
Country of origin	Switzerland	

Part Codes:

4-20mA Output:	
PL-528-1	Liquid pressure transmitter 0 to 1 bar
PL-528-1.6	Liquid pressure transmitter 0 to 1.6 bar
PL-528-2.5	Liquid pressure transmitter 0 to 2.5 bar
PL-528-4	Liquid pressure transmitter 0 to 4 bar
PL-528-6	Liquid pressure transmitter 0 to 6 bar
PL-528-10	Liquid pressure transmitter 0 to 10 bar
PL-528-16	Liquid pressure transmitter 0 to 16 bar
PL-528-25	Liquid pressure transmitter 0 to 25 bar
PL-528-40	Liquid pressure transmitter 0 to 40 bar
0-10Vdc Output:	
PL-528-1-V	Liquid pressure transmitter 0 to 1 bar
PL-528-1.6-V	Liquid pressure transmitter 0 to 1.6 bar
PL-528-2.5-V	Liquid pressure transmitter 0 to 2.5 bar
PL-528-4-V	Liquid pressure transmitter 0 to 4 bar
PL-528-6-V	Liquid pressure transmitter 0 to 6 bar
PL-528-10-V	Liquid pressure transmitter 0 to 10 bar
PL-528-16-V	Liquid pressure transmitter 0 to 16 bar
PL-528-25-V	Liquid pressure transmitter 0 to 25 bar
PL-528-40-V	Liquid pressure transmitter 0 to 40 bar

Accessories

PL-HS	Pressure transmitter heat sink
PL-528-CAL	Calibration certificate



The products referred to in this data sheet meet the requirements of EU Directive 2004/108/EC

Installation & Connections:


1. Fix the transmitter to the pipe using a ½" BSP female connection, and an isolation valve.
2. You should avoid mounting the transmitter where it will be subjected to mechanical vibration.
3. The sensor can be mounted in any orientation if the temperature is between -15 to 125°C.
4. Remove the DIN connector and expose the electrical terminals feed cable through the cable gland and connected as required (see connections below). Re-fit connector to transmitter.

- **PL-528-x (4-20mA):**

Terminal 1 7 - 33Vdc
Terminal 2 4-20mA signal

- **PL-528-x-V (0-10Vdc):**

Terminal 1 12 - 33Vdc or 24Vac ±15%
Terminal 2 0-10Vdc signal
Terminal 3 0V (Ground)



Tech Tip:

Effects of water hammer and pulsation.

By knowing and eliminating problems beforehand, you can avoid situations that will create water hammer or pulsation during a specific process, avoiding failed equipment and costly downtime.

Surge or water hammer, as it is commonly known is the result of a sudden change in liquid velocity. Water hammer usually occurs when a transfer system is quickly started, stopped or is forced to make a rapid change in direction. Any of these events can lead to catastrophic system component failure. Without question, the primary cause of water hammer in process applications is the quick closing valve, whether manual or automatic. A valve closing in 1.½ sec. or less depending upon valve size and system conditions causes an abrupt stoppage of flow. The pressure spike (acoustic wave) created at rapid valve closure can be high as five (5) times the system working pressure.

Pulsation generally occurs when a liquid's motive force is generated by reciprocating or peristaltic positive displacement pumps. It is most commonly caused by the acceleration and deceleration of the pumped fluid. This uncontrolled energy appears as pressure spikes. Vibration is the visible example of pulsation and is the culprit that usually leads the way to component failure.

Unlike centrifugal pumps (which produce normally non-damaging high-frequency but low-amplitude pulses), the amplitude is the problem because it's the pressure spike. The peak, instantaneous pressure required to accelerate the liquid in the pipe line can be greater than ten (10) times the steady state flow pressure produced by a centrifugal pump.

Whilst every effort has been made to ensure the accuracy of this specification, Sontay cannot accept responsibility for damage, injury, loss or expense from errors or omissions. In the interest of technical improvement, this specification may be altered without notice.

Tel: +44 (0)1732 861200. - **E-mail:** sales@sontay.com. - **Web:** www.sontay.com.

© 2012 Sontay Limited. All rights reserved